



Ref. No.: CRT-25-12

Date: 16-01-2025

BUILDING SAFETY CERTIFICATE

As per Guideline of Urban Development Department, Govt. of Maharashtra Dated 8th July 2011.

To,
The Principal,,
Buds International School
Dr. D.Y.Patil Shikshan Sanstha,
P.O. Newale Wasti, Chikhli,
Pune, Pin 412114.

Subject : Structural Stability Inspection and Building Safety Certification of Buds International School Building at P.O. Newale Wasti, Chikhli, Pune 412114.

Reference : Buds Int School/03 Dated- 10/01/2025

I/We, the undersigned are Empaneled Structural Auditor registered with Public Works Department, Govt of Maharashtra Having License No.643/2022, Pimpri Chinchwad Municipal Corporation having License No.08/2024, Pune Municipal Corporation (License No.637-B) and Chartered Engineer (IEI) AM145494-6.

I/We have been appointed as structural Auditor by The Principal, Buds International School, Dr. D.Y.Patil Shikshan Sanstha to carry out the Structural Stability Inspection and Building Safety Certification of the "School Building" situated at - "P.O. Newale Wasti, Chikhli, Pune 412114"

I/We have carried out structural examination of the aforesaid structure as per the procedure elaborated in the accompanying inspection report. I/We do hereby personally visited and checked all the structural component's of the structure. Also carried out Non destructive testing on Structure elements under our inspection and directions. (See Test Report attached to this report). On the basis of the detail examination and verification of the structure as required under provision of section 265A of the Bombay Provincial Municipal Corporation Act, 1949. I/We submit the following certificate:

"I/We KBP Civil Engineering services hereby certify that, Non- Destructive testing (Reports attached) carried out on various members of structure shows good quality of Material. The aforesaid structure shows of minor damages such as, Hair Line Cracks in Wall Masonry, Surface Cracks noted at few locations; Looking to the nature and extent thereof, the School building condition can be categorized as **STRUCTURALLY SAFE & STABLE**.

The next structural audit is required to be carried out on or before; 15 Jan 2026.

Sign of Approved Structural Engineer

Name: **Sunil B. Phulpagar**

M.Tech (Structures), B.Tech Civil

Regd No: PMC 0637-B, PCMC-12/2017

Lic No: PWD/643/2022 Dt. 31/01/2022

Chartered Engineer (IEI) AM145494-6

